

Table of Minimum Offsets

The following table of offsets gives the minimum required offsets for infrastructure across the major reviewing sections. Each tab is all-inclusive, meaning that all the offsets are self-contained in each tab. We have several tabs to facilitate ease of use, so if a surface drawing is being drafted or reviewed then the Complete Streets tab can be used easily, or if a landscaping drawing is being drafted or reviewed then the Landscaping tab can be used. These offsets are applicable to most cases. However, they may vary for infill or non-standard situations as existing conditions may require unique offsets, as determined by the City.

A design exception may be necessary to facilitate an implementable design or to introduce a non-traditional or alternative design that offers significantly improved performance. The Consolidated Design Exception Form will be utilized to evaluate and determine the performance, risk and mitigation strategies for design exceptions across Volumes 2, 3, 4, 5, 6 and 7 of the City and EPCOR Design and Construction Standards. This consolidated form replaces the individual design exception forms that were in use previously.

DISCLAIMER:

All information in this Table of Offsets has been gathered and amalgamated from Volumes 2,3,4,5,6 and 7 of the City and EPCOR Design and Construction Standards. Specific source volumes are specified in each tab of this workbook. As such, this is information only and does not require engineering authentication.

Version History

September 17, 2025 Version:

Addition of the Consolidated Design Exception Form

July 2, 2025 Version:

Various changes to EPCOR Water offsets to update offsets per new updated EPOR Water Standards

January 14, 2022 Version:

Disclaimer added and source volumes. Minor format changes.

June 30, 2021 Version:

Added "DPS" tab for Distribution Piping Systems for capital projects only

April 28, 2021 Version:

Various changes to EPCOR Water offsets to update offsets per new updated EPOR Water Standards

Pre April 28, 2021 version:

Originally released Table of Offsets

Domain: Complete Streets (Volume 2)				
Subdomain: Complete Streets (Volume 2)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	Data Source (Volumes from Standards)
Intersection edge of pavement	Traffic control cabinet	Located outside the Clear Sight Triangles to allow for required sightlines		2
Commercial/Industrial access edge of pavement	Traffic control cabinet	10.0m		
Curb Ramps	Commercial Crossing	1.0m	Flare to flare	
Shared-use paths, walkways, and sidewalks	Property line	0.3m	Property line to edge of shared-use path, walkway, or sidewalk	
Subdomain: EPCOR Drainage (Volume 3)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Face of Curb	Sanitary and storm mains	1.5m		2,3
Curb Ramps	Catchbasins and catchbasin manholes	0.5m		
Bus stop pad	Storm and sanitary services	1.5m	1.5 m from the edge of the bus stop pad, Drainage prefers sewer services to not to be buried under the bus stop pad	
Driveways	Catchbasins	1.5m	Edge of driveway.	
Intersection	Catchbasins	Locate at End of Curve OR Beginning of Curve and not within the curb ramp and crosswalk		
Subdomain: EPCOR Water (Volume 4)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
PL	Curb cock	0.1m	0.3m from PL for side lot services	2,4
Face of Curb (FOC)	Watermain	1.5m (<= 400 mm mains)		
FOC	Watermain	2.0m (> 400 mm mains)		
PL	Watermain in alley, utility lot, walkway, or URW	1.2m (preferably 2.0m)	Mains in walkways are to be dimensioned to side PL.	
PL	Water services	Extend service into lot 1.5m beyond the edge of the shallow utility easement	If the water service enters a parcel where there isn't a shallow utility easement, the water service shall extend into the lot a minimum of 1.5m beyond the property line.	
PL	Flushpoint	1.5m	Plug is 5.0m from PL	
FOC	Hydrant	Preferred: 3.0m for any ROW with Monowalk. Min 1.5 m - max 3.5 m offset acceptable.	If the monolithic walk is greater than 2.5 m wide, include a 90 degree bend in the hydrant lead and locate the hydrant and the control valve 0.3 m behind the back edge of the walk.	
FOC	Hydrant	1.5m for any ROW with Separate Walk	Where the walk is greater than 2.0 m into the boulevard or where no walk exists.	
Edge of Walk	Hydrant	0.3m		
Edge of Bus Stop	Hydrant	6.0m	Hydrants located within 45 m of the approach side of the bus stop or 15 m of the departure side must be labeled "To be white disked (Fire Dept. Use Only) at commissioning."	
Edge of Driveway	Hydrant	To be located on the opposite lot line from driveway	If unable, minimum 1.5m (preferably 2.0m)	
Corner of intersection	Hydrant	To be installed at the beginning of the curve of the curb return	Where not in conflict with item 4.2.14.	
Alley	Valves	6.0m of the approach & 3.0m of the departure		
Arterial road & collector road intersection	Valves	30m (edge to edge)		
Property Line	Valves	To be located on the projection of PL, where possible or dimension to a PL		
Utility lot, walkway or URW	Valves	0.5m from PL or its projection		
Subdomain: Landscaping (Volume 5)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
FOC (local)	Trees (centre of tree)	1.0m, 1.25m preferred	Trees to be placed in line with or further from Face of Curb than Streetlight Poles.	2,5
FOC (Collector)	Trees (centre of tree)	1.25m / 1.65m	1.25 m ROW < 20m, 1.65 m ROW > 20m. Trees to be placed in line with or further from Face of Curb than Streetlight Poles.	
FOC (Arterial)	Trees (centre of tree)	2.0m	Trees to be placed in line with or further from Face of Curb than Streetlight Poles.	
Intersection	Trees (centre of tree)	15m		
Edge of Sidewalk, Driveway, Walkway, and Shared-Use Path	Trees (centre of tree)	1.0m, preferred 1.5m		
Edge of Sidewalk, Walkway and Shared-Use Path	Shrubs	0.5m	Shrubs at maturity	
Edge of walk	Litter receptacle	0.6m		
Edge of commercial or industrial access	Trees (centre of tree)	1.5m		
Back of walkway	Benches	1.0m		
Back of walkway	Picnic Table	1.0m		
Boulevard curb	Mulched beds	2.5m	Within boulevard curb along arterial and collector roadways.	
Stop signs and yield signs	Trees (centre of tree)	3.5m		
All other signs	Trees (centre of tree)	2.0m		
Transit zones/bus pads	Trees (centre of tree)	3.5m	In addition to the 3.5 m clearance, ensure trees do not create sightline obstructions for vehicles approaching transit zones.	
Property line	Trees (centre of tree, in walkway or shared-use path ROW)	1.0m		
Property line	Trees (centre of tree, in boulevard)	1.0m		
Property Line	Deciduous trees (in open parkland)	2.5m	From centre of tree, in open parkland where there is turf between the fence and the tree rather than a bed.	
Property Line	Coniferous trees (in open parkland)	2.5m	From edge of mature spread of tree, in open parkland where there is turf between the fence and the tree rather than a bed.	
Subdomain: Streetlighting (Volume 6)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
FOC	Streetlight Pole (centre of pole)	1.25m along Local Streets; 1.25m along Collectors; 2.0m along Arterials; 2.6m for monowalks along Local and Collector Streets, 3.0m for monowalks adjacent to School Sites		2,6
FOC	Multiparty trench	2.5m	Centerline of trench	
Intersection	Streetlight Pole (centre of pole)	0.9m		
Edge of sidewalk or walkway	Streetlight Pole (centre of pole)	0.5m / preferred 1.0m		
Edge of shared-use paths	Streetlight Pole (centre of pole)	0.5m / preferred 1.5m		
Driveway (Residential)	Streetlight Pole (centre of pole)	0.5m with standard base and 0.75m with utility box		
Driveway/Access (Commerical or Industrial)	Streetlight Pole (centre of pole)	1.5m		
Subdomain: EPCOR Power (Volume 7)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
FOC	Multiparty trench	2.5m	Centerline of trench	2,7
FOC	Transformer	SEE NOTES	Offset is required. See the specific and applicable cross-section(s) found in Complete Streets Design and Construction Standards.	
Corner cut	Power crossings	3.0m		
Corner cut	Transformer	6.0m		
Corner cut	1-phase or 3-phase cubicle	30m		
Bus stop pad	Transformer/Switching cubicle	3.0m	From edge of bus pad to edge of base	
Road crossing	Transformer/Switching cubicle	3.0m	From centre to closest duct in crossing	
Transportation control devices and signs	Pad-mounted equipment	3.0m	From edge of pad	
Bus stop pad	Power crossings	3.0m	From edge of bus pad to crossing	
Residential driveways	Transformer	2.0m	From edge of equipment to driveway	
Intersection edge of pavement	Transformer/Switching cubicle	15m	From centre of transformer/switching cubicle	
Commercial/Industrial access edge of pavement	Transformer/Switching cubicle	10m		
Edge of walkway property line	Pad-mounted equipment	3.0m	From edge of equipment to edge of walkway property line	
PL	Main power/Multiparty trench	1.0m	Actual required minimum offset may change depending on sidewalk type and alignmnt of shallow utilities.	
Subdomain: Gas				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
FOC	Multiparty trench	2.5m	Centerline of trench	2
Subdomain: Telecommunications				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
FOC	Multiparty trench	2.5m	Centerline of trench	2
Subdomain: General				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Location of all surface appurtenances associated with underground utilities (including, but not limited to, transformers, cubicles, catch basins, manholes and utility covers, water valves, power/telecom vaults)	Active Transportation Infrastructure	Located outside of any sidewalks, shared-use paths, walkways, crosswalks, and curb ramps; See also the City's Design and Construction Standards Volumes 3, 4, and 7		2

Domain: EPCOR Drainage (Volume 3)				
Subdomain: Complete Streets and Roadways (Volume 2)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	Data Source (Volumes from Standards)
Storm and sanitary mains	Face of Curb	1.5m		2,3
Storm and sanitary services	Bus stop pad	1.5m	1.5 m from the edge of the bus stop pad, Drainage prefers sewer services are not to be buried under the bus stop pad	
Catchbasins and catchbasin manholes	Curb Ramps	0.5m		
Catchbasins	Driveways	1.5m	Edge of driveway.	
Catchbasins	Intersection	Locate at End of Curve OR Beginning of Curve and not within the curb ramp and crosswalk		
Subdomain: EPCOR Water (Volume 4)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Sanitary & Storm Main	Watermain	2.5m (preferably 3.0m)	Additional clearance may be required at the Engineer's (EWSI) discretion, including when pipe diameters are greater than 300 mm.	3,4
Sanitary Main, Storm Main and Catch Basin Leads Crossing	Watermain	0.3 m when crossing under water main (edge to edge) 0.5 m when crossing over water main (edge to edge)	Catch basin leads must be shown where they cross water mains.	
MH	Watermain	2.5m		
Oversized MH (Ø1800 & larger)	Watermain	3.0m	From the centreline to centreline (watermains <= 600 mm)	
Catch Basin	Watermain	1.5m		
Catch Basin lead	Watermain	2.5m (preferably 3.0m)		
Storm Sanitary service	Watermain	2.5m (preferably 3.0m)	When paralleling main	
Storm and Sanitary service crossing	Watermain	0.15m (edge to edge)	Vertical Crossing	
Storm Sanitary service	Large water service, Ø100 & larger	3.0m	Provide dimension from PL to services. Large water service to be in own trench.	
Storm Sanitary service	Water Services (50mm and smaller)	0.3 m	For typical dual and single services for single family, duplex, and semi-detached lots. Services 50mm and smaller to be laid in same trench as storm and sanitary services, to the right of the sanitary service when facing lot to be served. Water services 100mm and larger to be treated as watermains	
MH shaft	Water Services (50mm and smaller)	2.0m	Water services 100mm and larger to be treated as watermains	
Catch Basin	Water Services (50mm and smaller)	2.5m	Water services 100mm and larger to be treated as watermains	
Catch Basin lead	Water Services (50mm and smaller)	2.5m	Water services 100mm and larger to be treated as watermains	
Storm and Sanitary Main	Water Services (50mm and smaller)	1.5m (2.5m preferred)	For small services only (50mm and smaller). When paralleling. Water service cannot be between a storm main and a sanitary main. Water services 100mm and larger to be treated as watermains	
Storm and Sanitary joint	Water Services (50mm and smaller)	1.5m	Clearance is from joint, not centre of fitting (tee, cross, bend, etc.) Water services 100mm and larger to be treated as watermains	
Storm and Sanitary service	Hydrants	2.5m		
CB lead	Valve	3.0m		
Drainage Infrastructure or non-potable water infrastructure	Infrastructure with a thrust block (reducer, tee, cross or bend)	1.5m		
Drainage Infrastructure or non-potable water infrastructure including storm and sanitary services	Water Joint	1.5m	Clearance is from the joint not from the center of fitting (tee, cross, bend, etc.). Clearance also applies to tie in joints (i.e. plugs after BVs).	
Storm inline tee/ sanitary core-bell insert and service line	Water mainstop	0.3m		
Subdomain: Landscaping (Volume 5)				
Domain Infrastructure	Minimum Clearance	Minimum Clearance	Minimum Clearance	
Storm and sanitary services	Trees	1.8m	Centre of tree	3,5
Storm and sanitary manholes	Trees	1.8m	Centre of tree	
Subdomain: Streetlighting (Volume 6)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Storm and sanitary services	Streetlights and power poles	2.0m		3,6
Subdomain: EPCOR Power (Volume 7)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Drainage/Sanitary Main, Catch basin, manhole, vault other large drainage structure	Main power trench	2.0m	Troughed to 1.5 m either side of catch basin if less than 2.0 m	3,7
Manhole, catch basin, storm and sanitary services	1-phase pad-mounted equipment	4.5m	3.0 m is required from the ground grid to the other utility	
Manhole, catch basin, storm and sanitary services	3-phase pad-mounted equipment	5.0m	3.0 m is required from the ground grid to the other utility	
Catch basin, storm and sanitary services	Power crossings	3.0m	Crossings in roadways must be 3.0 m from catch basins	
Subdomain: Gas				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Storm and sanitary mains	Gas crossings and line	Minimum 1.5m, preferred 3.0m		3
Storm and sanitary services	Gas crossings and line	Minimum 1.5m, preferred 3.0m		
Catchbasins and catchbasin manholes	Gas crossings and line	Minimum 1.5m, preferred 3.0m		
Subdomain: Telecommunications				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Storm and sanitary mains	Telecommunications pedestal and line	Minimum 1.5m, preferred 3.0m		3
Storm and sanitary services	Telecommunications pedestal and line	Minimum 1.5m, preferred 3.0m		

Item Number	Domain: EPCOR Water (Volume 4)*				
	Subdomain: Complete Streets (Volume 2)				
	Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance **(Unless otherwise specified)	Notes	Data Source (Volumes from Standards)
4.2					2,4
4.2.1	Curb cock	PL	0.1m	0.3m from PL for side lot services	
4.2.2	Watermain	Face of Curb (FOC)	1.5m (<= 400 mm mains)		
4.2.3	Watermain	FOC	2.0m (> 400 mm mains)		
4.2.4	Watermain in alley, utility lot, walkway, or URW Water services (50mm and smaller)	PL PL	1.2m (preferably 2.0m) Extend service into lot 1.5m beyond the edge of the shallow utility easement	Mains in walkways are to be dimensioned to side PL. Water services 100mm and larger to be treated as watermains. If the water service enters a parcel where there isn't a shallow utility easement, the water service shall extend into the lot a minimum of 1.5m beyond the property line.	
4.2.5					
4.2.6	Flushpoint	PL	1.5m	Plug is 5.0m from PL	
	Hydrant	FOC	Preferred: 3.0m for any ROW with Monowalk. Min 1.5m - max 3.5m offset acceptable.	If the monolithic walk is greater than 2.5m wide, include a 90 degree bend in the hydrant lead and locate the hydrant and the control valve 0.3m behind the back edge of the walk.	
4.2.7					
4.2.8	Hydrant	FOC	1.5m for any ROW with Separate Walk	Where the walk is greater than 2.0 m into the boulevard or where no walk exists.	
4.2.9	Hydrant	Edge of Walk	0.3m		
	Hydrant	Edge of Bus Stop	6.0m	Hydrants located within 45m of the approach side of the bus stop or 15 m of the departure side must be labeled "To be white disked (Fire Dept. Use Only) at commissioning."	
4.2.10				If unable, minimum 1.5m (preferably 2.0m)	
4.2.11	Hydrant	Edge of Driveway	To be located on the opposite lot line from driveway		
4.2.12	Hydrant	Corner of intersection	To be installed at the beginning of the curve of the curb return	Where not in conflict with item 4.2.14.	
4.2.13	Valves	Alley	6.0m of the edge of approach & 3.0m of the edge of departure		
4.2.14	Valves	Arterial road & collector road intersection	30m (edge to edge)		
4.2.15	Valves	Property Line	To be located on the projection of PL, where possible or dimension to a PL		
4.2.16	Valves	Utility lot, walkway or URW	0.5m from PL or its projection		
	Subdomain: EPCOR Drainage (Volume 3)				
	Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance **(Unless otherwise specified)	Notes	
4.3					3,4
4.3.1	Watermain	Sanitary & Storm Main	2.5m (preferably 3.0m)	Additional clearance may be required at the Engineer's (EWSI) discretion,	
4.3.2	Watermain	Sanitary Main, Storm Main and Catch	0.3m when crossing under water main (edge to	Catch basin leads must be shown where they cross water mains.	
4.3.3	Watermain	MH	2.5m		
4.3.4	Watermain	Oversized MH (Ø1800 & larger)	3.0m	From the centreline to centreline (watermains <= 600mm)	
4.3.5	Watermain	Catch Basin	1.5m		
4.3.6	Watermain	Catch Basin lead	2.5m (preferably 3.0m)		
4.3.7	Watermain	Storm Sanitary service	2.5m (preferably 3.0m)	When paralleling main	
4.3.8	Watermain	Storm and Sanitary service crossing	0.15m (edge to edge)	Vertical Crossing	
4.3.9	Large water service, Ø100 & larger	Storm Sanitary service	3.0m	Provide dimension from PL to services. Large water service to be in own	
4.3.10	Water Services (50mm and smaller)	Storm Sanitary service	0.3m	For typical dual and single services for single family, duplex, and semi-	
4.3.11	Water Services (50mm and smaller)	MH shaft	2.0m	Water services 100mm and larger to be treated as watermains	
4.3.12	Water Services (50mm and smaller)	Catch Basin	2.5m	Water services 100mm and larger to be treated as watermains	
4.3.13	Water Services (50mm and smaller)	Catch Basin lead	2.5m	Water services 100mm and larger to be treated as watermains	
4.3.14	Water Services (50mm and smaller)	Storm and Sanitary Main	1.5m (2.5m preferred)	For small services only (50mm and smaller). When paralleling. Water service	
4.3.15	Water Services (50mm and smaller)	Storm and Sanitary joint	1.5m	Clearance is from joint, not centre of fitting (tee, cross, bend, etc.)	
4.3.16	Hydrants	Storm and Sanitary service	2.5m		
4.3.17	Valve	CB lead	3.0m		
4.3.18	Infrastructure with a thrust block (reducer, tee,	Drainage Infrastructure or non-	1.5m		
4.3.19	Water Joint	Drainage Infrastructure or non-	1.5m	Clearance is from the joint not from the center of fitting (tee, cross, bend, etc.).	
4.3.20	Water mainstop	Storm inline tee/ sanitary core-bell	0.3m		
	Subdomain: General / EPCOR Water (Volume 4)				
	Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance **(Unless otherwise specified)	Notes	
4.4					4
4.4.1	Watermain	Watermain	1.5m	If the carriageway allows for two water mains to be located within the street or	
4.4.2	Watermain	Any other utility crossing the water	1.0m vertical (edge to edge)	Does not include storm and sanitary sewer mains and DPS mains.	
4.4.3	Tapping Valve Sleeve (TVS) - 300mm or smaller	All pipe joints, including other	1.0m		
4.4.4	Tapping Valve Sleeve (TVS) - 350mm or larger	All pipe joints, including other	1.5m		
4.4.5	Water mainstop	To other mainstop including adjacent	0.6m		
4.4.6	Water mainstop	From any water joint i.e., bend, tee,	0.6m		
4.4.7	Water mainstop	Storm inline tee/ sanitary core-bell	0.3m		
4.4.8	Water Main and Any Utility Crossing	Deflection or joint on either utility	1.5m horizontal separation	All crossings shall be at 90 degrees to the water infrastructure. If this cannot	
	Subdomain: Landscaping (Volume 5)**				
	Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
4.5					4,5
4.5.1	All water infrastructure	Soil cells	See Volume 4 Section 1.15		
4.5.2	Valve, hydrant, curb cock (CC), or watermain	Fence	1.2m	For fencing on private property, offset for fencing on public property will be at	
4.5.3	Watermains, services, manual air vents	Deciduous tree	1.8m	Ensure that these dimensions are measured from the actual service locations	
4.5.4	Watermains, Services, manual air vents	Coniferous tree	3.5m	Ensure that these dimensions are measured from the actual service locations	
4.5.5	Hydrant	Deciduous tree	3.5m		
4.5.6	Hydrant	Coniferous tree	7.0m		
4.5.7	Hydrant	Shrubs	1.0m behind hydrant and 1.5 m on either side of the		
4.5.8	Valve, hydrant, curb cock (CC), or watermain	Movable street and parks furniture	1.5m		
4.5.9	Valve, hydrant, curb cock (CC), or watermain	Immovable street and parks furniture	3.0m		
4.5.10	Provide a dimension from the landscaping element to the water appurtenance if: Within 3.0m of water service Within 5.0m of valve, hydrant or curb cock or any other infrastructure				
	Subdomain: Streetlighting (Volume 6)				
	Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
4.6					4,6
4.6.1	Hydrant	Streetlight pole (centre of pole)	1.8m	Edge to edge with pedestal, transformer, telecommunication cubicles &	
4.6.2	Water services (50mm and smaller)	Streetlight pole (centre of pole)	1.8m	Water services 100mm and larger to be treated as watermains	
4.6.3	Watermain	Streetlight pole (centre of pole)	1.8m		
	Subdomain: EPCOR Power (Volume 7)				
	Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
4.7					4,7
4.7.1	Water services and hydrants/flush points/air	1-phase pad-mounted equipment	4.5m		
4.7.2	Water services and hydrants/flush points/air	3-phase pad-mounted equipment	5.0m		
4.7.3	Water services (50mm and smaller)	Power services and Power Cables	1.8m	Clearance is from the actual water service location, not from the water service	
4.7.4	Valves and curb cocks	Power cables <= 40 kV	1.0m	Minimum distance between CC and any power cables. Telecommunication	
4.7.5	Valve or water appurtenances is crossed on both	Power cables <= 40 kV	1.8m		
4.7.6	Valve casings	Pad-mounted equipment	1.5m	Edge to edge	
4.7.7	Hydrants with control valves more than 2m from	Power cables <= 40 kV crossing	Hydrants: 3m	Hydrant:	
4.7.8	Hydrants	Main power cable and duct bank	3.0m	See EDTI Standard for Trenching Around Hydrants for reduced clearances	
4.7.9	Hydrants	Power cables <= 40 kV	3.0m	1.0m is allowed if encased in wood, trough to 1.5m on each side of hydrant	
4.7.10	Watermain	Secondary Power Cable (<=750 V)	2m from edge of pipe	Water services 100mm and larger to be treated as watermains	
	Watermain and Water services	Primary Power Cable (<=40 kV)	4m from edge of pipe	Primary power to be located on opposite side of the road unless power is in a four party trench or otherwise approved by the Engineer.	
4.7.11					
4.7.12	Watermain and Water services	High Voltage Power Cable (>40 kV)	See Notes	To be designed based on safe limits of approach and excavation allowance.	
4.7.13	Watermain	Pad-mounted equipment	3.0m		
4.7.14	All water infrastructure	Grounding rods	1.8m		
4.7.15	Watermain and Water services	Power poles, pole anchors	1.8m		
	Subdomain: Gas				
	Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
4.8					4
4.8.1	Watermain	Gas main	1.8m		
4.8.2	Valve or curb cock (CC)	Gas mains or ductlines	1.0m		
4.8.3	Valve or water appurtenances is crossed on both	Gas mains or ductlines	1.8m		
4.8.4	Hydrant	Gas mains or ductlines	1.5m	1.0m is allowed if encased in wood, trough to 1.5m on each side of hydrant	
4.8.5	Hydrants with control valves more than 2m from	Gas mains or ductlines crossing	Hydrants: 3m	Hydrant:	
4.8.6	Water services (50mm and smaller)	Gas services and gas crossings	1.8m	Clearance is from the actual water service location, not from the water service	
4.8.7	Water services (50mm and smaller)	Gas mains or ductlines	1.8m	Water services 100mm and larger to be treated as watermains	
	Subdomain: Telecommunications				
	Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
4.9					4
4.9.1	Watermain	Telecommunication cable, cubicles,	1.8m		
4.9.2	Valve or curb cock (CC)	Telecommunication cable	1.0m		
4.9.3	Hydrant	Telecommunication cable	1.5m	1.0m is allowed if encased in wood, trough to 1.5m on each side of hydrant	
4.9.4	Valve or water appurtenances is crossed on both	Telecommunication cable	1.8m		
4.9.5	Hydrants with control valves more than 2m from	Telecommunication cable crossing	Hydrants: 3m	Hydrant:	
4.9.6	Water services (50mm and smaller)	Telecommunication cable, cubicles,	1.8m	Water services 100mm and larger to be treated as watermains	

* Table of Offsets provided assuming existing PVC water pipe (<= 300 mm), proximity to other pipe materials subject to EPCOR Water Services review and may require increased clearances. All clearances are center to center unless otherwise specified.

** Dimension symbol and legend can be used instead of dimension line to avoid clutter.

Domain: DPS Systems (Volume 1)* (SEE ADDITIONAL NOTES AT THE BOTTOM)				
Subdomain: Complete Streets (Volume 2)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance *(Unless otherwise specified)	Notes	Data Source (Volumes from Standards)
Curb cock	PL	0.1m	0.3m from PL for side lot services	District Energy Sharing Systems Standards, 2
DPS Main/Branch	Face of Curb (FOC)	1.5m (<= 400 mm mains)		
DPS Main/Branch	FOC	2.0m (> 400 mm mains)		
DPS Main/Branch in alley, utility lot, walkway, or URW	PL	1.2m (preferably 2.0m)	Mains in walkways are to be dimensioned to side PL.	
DPS Services	PL	Extend service into lot a minimum of 1.5m beyond the edge of the shallow utility easement	If the DPS service enters a parcel where there isn't a shallow utility easement, the DPS service shall extend into the lot a minimum of 1.5m beyond the property line.	
Blow-off/Drain Manhole	PL	1.5m from centerline of blow-off air vent to PL		
Valves	Alley	6.0m of the approach & 3.0m of the departure		
Valves	Arterial road & collector road intersection	30m		
Valves	Property Line	To be located on the projection of PL, where possible or dimension to a PL		
Valves	Utility lot, walkway or URW	0.5m from PL or its projection		
Subdomain: EPCOR Drainage (Volume 3)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance *(Unless otherwise specified)	Notes	
DPS Main/Branch	Sanitary & Storm Main	2.5m (preferably 3.0m)	Additional clearance may be required at the Engineer's discretion, including when pipe diameters are greater than 300 mm.	District Energy Sharing Systems Standards, 3
DPS Main/Branch	Sanitary Main, Storm Main and Catch Basin Leads Crossing	0.3 m when crossing under DPS main/branch 0.5 m when crossing over DPS main/branch	Catch basin leads must be shown where they cross DPS main/branch.	
DPS Main/Branch	MH	2.5m		
DPS Main/Branch	Oversized MH (Ø1800 & larger)	3.0m	From the centreline to centreline (DPS main/branch <= 600 mm)	
DPS Main/Branch	Catch Basin	1.5m		
DPS Main/Branch	Catch Basin lead	2.5m (preferably 3.0m)		
DPS Main/Branch	Storm Sanitary service	2.5m (preferably 3.0m)	When paralleling main	
DPS Main/Branch	Storm and Sanitary service crossing	0.15m	Vertical Crossing	
DPS service, Ø100 & larger	Storm Sanitary service	3.0m	Provide dimension from PL to services. Large DPS service to be in own trench.	
DPS Services	Storm Sanitary service	0.3 m	For typical dual and single services for single family, duplex, and semi-detached lots. Services 50mm and smaller to be laid in same trench as storm, sanitary, and water services.	
DPS Services	MH shaft	2.0m		
DPS Services	Catch Basin	2.5m		
DPS Services	Catch Basin lead	2.5m		
DPS Services	Storm and Sanitary Main	1.5m (2.5m preferred)	For small services only (50mm and smaller). When paralleling.	
DPS Services	Storm and Sanitary joint	1.5m	Clearance is from joint, not centre of fitting (tee, cross, bend, etc.)	
DPS MH	Sanitary & Storm Main	2.5m		
Valve	CB lead	3.0m		
Infrastructure with a thrust block (reducer, tee, cross or bend)	Drainage Infrastructure or non-potable water infrastructure	1.5m		
Subdomain: General / EPCOR Water (Volume 4)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance *(Unless otherwise specified)	Notes	
DPS Main/Branch	Watermain	2.5m (preferably 3.0m)	Additional clearance may be required at the Engineer's discretion, including when pipe diameters are greater than 300 mm.	District Energy Sharing Systems Standards, 4
DPS Main/Branch	Watermain	0.3 m when crossing under DPS main/branch 0.5 m when crossing over DPS main/branch	The DPS main should have the following clearances: 0.3 m when DPS is crossing under water main 0.5 m when DPS is crossing over water main (measured from water main crown to DPS invert) It is preferred that water mains cross over non-potable mains when possible.	
DPS Main/Branch	Watermain service	2.5m (preferably 3.0m)	When paralleling main	
DPS MH	Watermain	2.5m		
Oversized MH (Ø1800 & larger)	Watermain	3.0m	From the centreline to centreline (DPS mains or branch <= 600 mm)	
DPS Service Crossing	Watermain	0.15m	Vertical Crossing	
DPS Service	Large water service, Ø100 & larger	3.0m	Provide dimension from PL to services. Large water DPS service to be in own trench.	
DPS Service	Water Services	0.3m	For typical dual and single services for single family, duplex, and semi-detached lots. Services 50mm and smaller to be laid in same trench as storm, sanitary, and water services.	
DPS MH Shaft	Water Services	2.0m		
DPS Main/Branch	Water Services	1.5m (2.5m preferred)	For small services only (50mm and smaller). When paralleling.	
DPS joint	Water Services	1.5m	Clearance is from joint, not centre of fitting (tee, cross, bend, etc.)	
DPS Service	Hydrants	2.5m		
DPS Service	Infrastructure with a thrust block (reducer, tee, cross or bend)	1.5m		
DPS Service	Water Joint	1.5m	Clearance is from the joint not from the center of fitting (tee, cross, bend, etc.). Clearance also applies to tie in joints (i.e. plugs after BVs). If a DPS main is crossing a WM it needs to be 1.5 m from any water joints.	
DPS Service	Water mainstop	0.3m		
Subdomain: Landscaping (Volume 5)*				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
All DPS infrastructure	Soil cells	1.5m (2.5 preferred)	Soil cells not permitted above DPS Mains/Branches	District Energy Sharing Systems Standards, 5
DPS Main/Branch, Services, Manual air vents, MH	Fence	1.2m	For fencing on private property, offset for fencing on public property will be at 1.2m or greater, at the discretion of the City	
DPS Main/Branch, Services, Manual air vents, MH	Deciduous tree	1.8m	Ensure that these dimensions are measured from the actual service locations and not the property line.	
DPS Main/Branch, Services, Manual air vents, MH	Coniferous tree	3.5m	Ensure that these dimensions are measured from the actual service locations and not the property line.	
Valve, curb cock (CC), DPS Main/Branch, Manual air vents, MH	Movable street and parks furniture including but not limited to benches, tables, and waste receptacles	1.5m		
DPS Valve, DPS curb cock (CC), DPS Main/Branch, manual air vents, MH	Immovable street and parks furniture including but not limited to signs, public art, and retaining walls	3.0m		
Subdomain: Streetlighting (Volume 6)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
DPS Main/Branch, Services, Manual air vents, MH	Streetlight pole (centre of pole)	1.8m	Edge to edge with pedestal, transformer, telecommunication cubicles & streetlightlight poles	District Energy Sharing Systems Standards, 6
DPS services	Streetlight pole (centre of pole)	1.8m		
DPS Main/Branch	Streetlight pole (centre of pole)	1.8m		
Subdomain: EPCOR Power (Volume 7)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
DPS Services, blow-offs, MH, Manual air vents	1-phase pad-mounted equipment (transformers)	4.5m	This is the typical offset. However, deviation from this offset may be required at the discretion of EPCOR D&T and will be determined during Engineering Drawing review.	District Energy Sharing Systems Standards, 7
DPS Services, blow-offs, MH, Manual air vents	3-phase pad-mounted equipment (transformers)	5.0m	This is the typical offset. However, deviation from this offset may be required at the discretion of EPCOR D&T and will be determined during Engineering Drawing review.	
DPS Services	Power services and Power Cables Paralleling Water Service	1.8m		
DPS Valves and DPS curb cocks	Power cables <= 40 kV	1.0m	Minimum distance between CC and any power cables. Telecommunication cables, gas mains, duct lines	
DPS Valve or DPS appurtenances is crossed on both sides	Power cables <= 40 kV	1.8m		
DPS Valve casings	Pad-mounted equipment	1.5m	Edge to edge	
DPS MH	Main power cable and duct bank	3.0m	See EDTI Standard for Trenching Around Hydrants for reduced clearances (Volume 7: EDTI Standards)	
DPS MH	Power cables <= 40 kV	3.0m	1.0m is allowed if encased in wood, trough to 1.5m on each side of hydrant	
DPS Main/Branch	Secondary Power Cable (<=750 V)	2 m from edge of pipe		
DPS Main/Branch	Primary Power Cable (<=40 kV)	4 m from edge of pipe	Primary power to be located on opposite side of the road unless power is in a four party trench or otherwise approved by the Engineer.	
DPS Main/Branch	High Voltage Power Cable (>40 kV)	See Notes	To be designed based on safe limits of approach and excavation allowance.	
DPS Main/Branch	Pad-mounted equipment	3.0m	If DPS Main runs in the boulevard, deviation from this offset may be required at the discretion of EPCOR D&T and will be determined during Engineering Drawing review.	
All DPS infrastructure	Grounding rods	1.8m		
Subdomain: Gas				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
DPS Main/Branch	Gas main	1.8m		District Energy Sharing Systems Standards
DPS Valve or curb cock (CC)	Gas mains or ductlines	1.0m		
DPS Valve or DPS appurtenances is crossed on both sides	Gas mains or ductlines	1.8m		
DPS MH	Gas mains or ductlines	1.5m	1.0m is allowed if encased in wood, trough to 1.5m on each side of hydrant	
DPS Services	Gas services and gas crossings	1.8m		
DPS Services	Gas mains or ductlines	1.8m		
Subdomain: Telecommunications				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
DPS Main/Branch	Telecommunication cable, cubicles, poles and pedestals	1.8m		District Energy Sharing Systems Standards
Valve or curb cock (CC)	Telecommunication cable	1.0m		
DPS MH	Telecommunication cable	1.5m	1.0m is allowed if encased in wood, trough to 1.5m on each side of hydrant	
DPS Valve or DPS appurtenances is crossed on both sides	Telecommunication cable	1.8m		
DPS Services	Telecommunication cable, cubicles, poles and pedestals	1.8m		
Subdomain: General /DPS				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance *(Unless otherwise specified)	Notes	
DPS Main/Branch	DPS Main/Branch	Refer to DPS Standard Detail C-15	Clearance between supply and return mains	District Energy Sharing Systems Standards
DPS Service Connection at the Main/Branch	To other connects including adjacent fittings, valves, etc.	0.6m		

Domain: Landscaping (Volume 5) (SEE ADDITIONAL NOTES AT THE BOTTOM)				
Subdomain: Complete Streets and Roadways (Volume 2)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	Data Source (Volumes from Standards)
Trees	Face of Curb (Local)	1.0m, 1.25m preferred	Trees to be placed in line with or further from Face of Curb than Streetlight Poles.	2,5
Trees	Edge of Sidewalk, Walkway, Driveway, and Shared-Use Path	1.0m, preferred 1.5m		
Trees	FOC (Collector)	1.25m / 1.65m	1.25 m ROW < 20m, 1.65 m ROW > 20m. Trees to be placed in line with or further from Face of Curb than Streetlight Poles.	
Trees	FOC (Arterial)	2.0m	Trees to be placed in line with or further from Face of Curb than Streetlight Poles.	
Trees	Edge of commercial or industrial access	1.5m		
Trees	Stop signs and yield signs	3.5m		
Trees	All other signs	2.0m		
Trees	Transit zones/bus pads	3.5m	In addition to the 3.5 m clearance, ensure trees do not create sightline obstructions for vehicles approaching transit zones.	
Trees	Intersection	15m		
Trees (in walkway or shared-use path ROW)	Property line	1.0m		
Trees (in boulevard)	Property line	1.0m		
Deciduous trees (in open parkland)	Property line	2.5m	From centre of tree, in open parkland where there is turf between the fence and the tree rather than a bed.	
Coniferous trees (in open parkland)	Property line	2.5m	From edge of mature spread of tree, in open parkland where there is turf between the fence and the tree rather than a bed.	
Shrubs	Edge of Sidewalk, Walkway and Shared-Use Path	0.5m	Shrubs at maturity.	
Mulched beds	Boulevard curb	2.5m	Within boulevard curb along arterial and collector roadways.	
Benches	Back of walkway	1.0m		
Litter receptacle	Edge of Walk	0.6m		
Picnic Table	Back of walkway	1.0m		
Subdomain: EPCOR Drainage (Volume 3)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Trees	Storm and sanitary services	1.8m		3,5
Trees	Storm and sanitary manholes	1.8m		
Subdomain: EPCOR Water (Volume 4)****				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Soil cells	All water infrastructure	See Volume 4 Section 1.15		4,5
Fence	Valve, hydrant, curb cock (CC), or watermain	1.2m	For fencing on private property, offset for fencing on public property will be at 1.2m or greater, at the discretion of the City	
Deciduous tree	Watermains, services, manual air vents	1.8m	Ensure that these dimensions are measured from the actual service locations and not the property line.	
Coniferous tree	Watermains, Services, manual air vents	3.5m	Ensure that these dimensions are measured from the actual service locations and not the property line.	
Deciduous tree	Hydrant	3.5m		
Coniferous tree	Hydrant	7.0m		
Shrubs	Hydrant	1.0 m behind hydrant and 1.5 m on either side of the hydrant (extending to road)		
Movable street and parks furniture including but not limited to benches, tables, and waste receptacles	Valve, hydrant, curb cock (CC), or watermain	1.5m		
Immovable street and parks furniture including but not limited to signs, public art, and retaining walls	Valve, hydrant, curb cock (CC), or watermain	3.0m		
Provide a dimension from the landscaping element to the water appurtenance if: Within 3.0 m of water service Within 5.0 m of valve, hydrant or curb cock or any other infrastructure				
Subdomain: Landscaping (Volume 5)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Shrub beds and planting beds	Shrub bed, fence, furniture, buildings, trees, and any other obstruction	2.5m		5
Shrub beds, planting beds, and trees	Any play space envelope (playground equipment and splash parks)	5m		
Shrub beds and planting beds	Edge of bed	0.5m	Must be 500 mm (0.5 m) of mulched space between the edge of the mature shrub and the edge of the bed	
Coniferous Tree	Edge of bed	0.5m	Must be 500 mm (0.5 m) of mulched space between the edge of the mature coniferous tree and the edge of the bed	
Litter receptacle	Bench	3.0m		
Subdomain: Landscaping Offleash Areas (Volume 5)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Offleash Area	Residential Areas and cemeteries (property line)	100m	Unless separated a berm, fencing, trees or other mitigation measures and at the discretion of the City.	N/A (these specific offsets in Table of Offsets only)
Offleash Area	Arterial roads	50m	Unless separated by fencing or other mitigation methods and at the discretion of the City	
Offleash Area	Golf Courses and public areas that attract high concentrations of people	50m	Unless separated by fencing or other mitigation methods and at the discretion of the City	
Offleash Area	Multi-use trails and equestrian trails	25m	Unless separated by fencing or other mitigation methods and at the discretion of the City	
Offleash Area	School grounds or play areas and associated walking routes	25m	Unless separated by fencing or other mitigation methods and at the discretion of the City	
Offleash Area	Pools, splash parks, sports fields, and picnic areas	25m	Unless separated by fencing or other mitigation methods and at the discretion of the City	
Offleash Area	Natural areas, wildlife corridors, and other environmentally sensitive areas	Determine case by case	As determined on a case by case basis with the City	
Subdomain: Streetlighting (Volume 6)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Trees	Streetlights and power poles	3.0m		5,6
Trees	Streetlight cable	1.0m	For arterial road boulevards	
Subdomain: EPCOR Power (Volume 7)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Trees	Main power trench	1.0m	Measured from the main power cable.	5,7
Trees and shrubs	3-phase switching cubicle	3.0m on each side where doors open	From edge of base	
Trees and shrubs	Transformer	2.0m on sides 3.0m in front of doors 1.5m behind base	Measured from edge of base Minimum 3.0 m clearance in front of doors required for hot stick operation Measured from edge of base	
Trees and shrubs	Power crossings	1.0m	Measured horizontally offset from the power crossing alignment	
Trees and shrubs	1-phase switching cubicle	3.0m front 4.0m sides 2.5m behind base	From edge of base	
Landscaped road island	Power crossings	SEE NOTES	See Note 1 below	
Landscaped road island	Pad-mounted equipment	SEE NOTES	See Note 1 below	
Subdomain: Gas and Pipelines				
Trees	Contact the utility for setbacks			
Trees, shrubs, shrub and planting beds	Pipelines	Planting distances from low, intermediate and high-pressure pipelines are to be observed as dictated by the Pipeline Authority.		N/A
Subdomain: Telecommunications				
Trees	Contact telecomm company for setbacks			N/A

ADDITIONAL NOTES

*For deciduous tree(s), all measurements from centre of tree(s), for coniferous trees all measurements are from the edge of the mature spread, unless stated explicitly otherwise	
** In general, setback distances apply to the majority of tree and tree form shrub species. However, certain species require different setbacks, such as those trees with suckering root systems or large hanging canopies (i.e. Poplars and Willows). Planting Populus spp. on parkland adjacent to private property is generally not recommended. However.	
- Should Northwest Poplar, Balsam Poplar and Cottonwood be referenced, the minimum setback distances from private property lines shall be 15m due to root encroachment concerns.	- All other Populus spp., including columnar varieties, shall have a minimum setback of 10m from private property lines and 5.0m from hard surface areas where sub surface compaction has occurred.
- Should Northwest Poplar, Balsam Poplar and Cottonwood be referenced, the minimum setback distances from private property lines shall be 15m due to root encroachment concerns.	- Should Northwest Popular, Balsam Popular and Cottonwood be referenced, the minimum setback distances from hard surfaces shall be 10m, unless special construction details are used.
- Some allowances may be made at the discretion of Forestry at th City if there is special construction mitigation in place, such as a root barrier.	
*** Some offsets related to constrution practices (not design offsets) are provided in Volume 5: Landscaping. These must be adhered to by the Developer, Contractor, and Consultant. See Volume 5: Landscaping "Trees and Shrub Planting Setbacks" for further information.	
**** Dimension symbol and legend can be used instead of dimension line to avoid clutter.	
Note 1: See the City of Edmonton Design and Construction Standards Volume 5 – Landscaping ...shallow utilities shall not be placed in Landscaped Road Islands. Written permission for power crossings or pad mounted equipment in Landscaped Road Islands is the responsibility of the developer. Ducts must be continuous and cannot have trees within 1.0 m of the duct. Other plantings such as small shrubs or flowers would be allowed over top of the crossing.	
Distances from overhead power utilities shall be as per the requirements established by the Utility Authority.	

Domain: Streetlighting (Volume 6)*				
Subdomain: Complete Streets (Volume 2)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	Data Source (Volumes from Standards)
Streetlight Pole	FOC	1.25m along Local Streets; 1.25m along Collectors; 2.0m along Arterials; 2.6m for monowalks along Local and Collector Streets 3.0m for monowalks adjacent to School Sites		2,6
Streetlight Pole	Edge of sidewalk or walkway	0.5m , preferred 1.0m		
Streetlight Pole	Edge of shared-use path	0.5m, preferred 1.5m		
Streetlight Pole	Intersection	0.9m		
Streetlight Pole	Driveway (Residential)	0.5m with standard base and 0.75m with utility box	Edge of driveway	
Streetlight Pole	Driveway/Access (Commerical or Industrial)	1.5m	Edge of access	
Multiparty trench	FOC	2.5m	Centerline of trench	
Subdomain: EPCOR Drainage (Volume 3)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Streetlights and power poles	Storm and sanitary services	2.0m		3,6
Subdomain: EPCOR Water (Volume 4)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Streetlight Pole (centre of pole)	Hydrant	1.8m	Edge to edge with pedestal, transformer, telecommunication cubicles & streetlightlight poles	4,6
Streetlight Pole (centre of pole)	Water services (50mm and smaller)	1.8m	Water services 100mm and larger to be treated as watermains	
Streetlight Pole (centre of pole)	Watermain	1.8m		
Subdomain: Landscaping (Volume 5)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Streetlight Pole	Trees	3.0m		5,6
Streetlight Cable	Trees	1.0m	For arterial road boulevards	
Subdomain: EPCOR Power (Volume 7)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Streetlight Pole	Primary or secondary cables	1.0m / 0.3m	1.0 m clearance required if streetlighting is installed after power is installed. 300 mm clearance required if streetlighting is installed at the same time as the power is installed. See standard for trenching around street light pole bases (Volume 7: EPCOR D&T)	6,7
Streetlight Pole	Power crossings	1.5m	To the closest power crossing duct	
Main streetlight trench	Pad-mounted equipment	Common trench	See base standards and trough standards (Volume 7: EPCOR D&T)	
Subdomain: Gas				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Streetlight Pole	Gas crossings and lines	1.0m		6
Subdomain: Telecommunications				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Streetlight Pole	Telecommunication lines and pedestals	1.0m		6

*All measurements from centre of pole

Domain: EPCOR Distribution and Transmission (Volume 7) (SEE ADDITIONAL NOTES AT THE BOTTOM)				
Subdomain: Complete Streets and Roadways (Volume 2)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	Data Source (Volumes from Standards)
Transformer	Corner cut	6.0m		2,7
Transformer	FOC	SEE NOTES	Offset is required. See the specific and applicable cross-section(s) found in Complete Streets Design and Construction Standards.	
Transformer	Residential driveways	2.0m	From edge of equipment to driveway	
Transformer/Switching cubicle	Bus stop pad	3.0m	From edge of bus pad to edge of base	
Transformer/Switching cubicle	Road crossing	3.0m	From centre to closest duct in crossing	
Transformer/Switching cubicle	Intersection edge of pavement	15.0m		
Transformer/Switching cubicle	Commercial/Industrial access edge of pavement	10.0m		
Pad-mounted equipment	Edge of walkway property line	3.0m	From edge of equipment to edge of walkway property line	
Pad-mounted equipment	Transportation control devices and signs	3.0m	From edge of pad	
1-phase or 3-phase cubicle	Corner cut	30.0m		
Multiparty Trench	FOC	2.5m	Centerline of trench	
Main power/multiparty trench	Property Line	1.0m	Actual required minimum offset may change depending on sidewalk type and alignment of shallow utilities.	
Power crossings	Bus stop pad	3.0m	From edge of bus pad to crossing	
Power crossings	Corner cut	3.0m		
Subdomain: EPCOR Drainage(Volume 3)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Main Power Trench	Drainage/Sanitary Main, Catch basin, manhole, vault other large drainage structure	2.0m	Troughed to 1.5 m either side of catch basin if less than 2.0 m	3,7
1-phase pad-mounted equipment	Manhole, catch basin, storm and sanitary services	4.5m	3.0 m is required from the ground grid to the other utility	
3-phase pad-mounted equipment	Manhole, catch basin, storm and sanitary services	5.0m	3.0 m is required from the ground grid to the other utility	
Power crossings	Catch basin, storm and sanitary services	3.0m	Crossings in roadways must be 3.0 m from catch basins	
Subdomain: EPCOR Water (Volume 4)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
1-phase pad-mounted equipment (transformers)	Water services and hydrants/flush points/air vents	4.5m		4,7
3-phase pad-mounted equipment (transformers)	Water services and hydrants/flush points/air vents	5.0m		
Power services and Power Cables Paralleling Water Service	Water services (50mm and smaller)	1.8m	Clearance is from the actual water service location, not from the water service symbol Water services 100mm and larger to be treated as watermains	
Power cables <= 40 kV	Valves and curb cocks	1.0m	Minimum distance between CC and any power cables. Telecommunication cables, gas mains, duct lines	
Power cables <= 40 kV	Valve or water appurtenances is crossed on both sides	1.8m		
Pad-mounted equipment	Valve casings	1.5m	Edge to edge	
Power cables <= 40 kV crossing between control valve and hydrant	Hydrants with control valves more than 2m from hydrant	Hydrants: 3m Valves 1.0m	Hydrant: 1.0m is allowed if encased in wood, trough to 1.5m on each side of hydrant	
Main power cable and duct bank	Hydrants	3.0m	See EDTI Standard for Trenching Around Hydrants for reduced clearances (Volume 7: EDTI Standards)	
Power cables <= 40 kV	Hydrants	3.0m	1.0m is allowed if encased in wood, trough to 1.5m on each side of hydrant	
Secondary Power Cable (<=750 V)	Water Main	2 m from edge of pipe	Water services 100mm and larger to be treated as watermains	
Primary Power Cable (<=40 kV)	Water Main	4 m from edge of pipe	Primary power to be located on opposite side of the road unless power is in a four party trench or otherwise approved by the Engineer.	
High Voltage Power Cable (>40 kV)	Water Main	See Notes	To be designed based on safe limits of approach and excavation allowance.	
Pad-mounted equipment	Watermain	3.0m		
Grounding rods	All water infrastructure	1.8m		
Power Poles and Pole Anchors	Watermain and Water services	1.8m		
Subdomain: Landscaping (Volume 5)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Main power trench	Trees	1.0m	Measured from the main power cable.	5,7
1-phase switching cubicle	Trees and shrubs	3.0m front 4.0m sides 2.5m behind base	From edge of base	
3-phase switching cubicle	Trees and shrubs	3.0m on each side where doors open	From edge of base	
Pad-mounted equipment	Landscaped road island	SEE NOTES	See Note 1 below	
Transformer	Trees and shrubs	2.0m on sides 3.0m in front of doors 1.5m behind base	Measured from edge of base Minimum 3.0 m clearance in front of doors required for hot stick operation Measured from edge of base	
Power crossings	Trees and shrubs	1.0m	Measured horizontally offset from the power crossing alignment	
Power crossings	Landscaped road island	SEE NOTES	See Note 1 below	
Subdomain: Street Lighting (Volume 6)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Pad-mounted equipment	Main streetlight trench	Common trench	See base standards and trough standards (Volume 7: EPCOR D&T)	6,7
Primary or secondary cables	Streetlight Davit Poles or Contactors	1.0m / 0.3m	1.0 m clearance required if streetlighting is installed after power is installed. 300 mm clearance required if streetlighting is installed at the same time as the power is installed. See standard for trenching around street light pole bases (Volume 7: EPCOR D&T)	
Power crossings	Streetlight Davit Poles or Contactors	1.5m	To the closest power crossing duct	
Subdomain: Gas				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Pad-mounted equipment	Gas crossing	3.5m	From centre of equipment (minimum 2.0 m grom ground grid)	7
Pad-mounted equipment ground grid	Main gas trench	1.0m	From ground grid to gas line trench	
Main power trench	Main	1.0m	Parallel, see Note 2 below	
Power crossings	Main	1.0m	Parallel	
Power crossings	Main or service	300mm	Without mechanical separation, see Note 3 below	
Subdomain: Telecommunications				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Pad-mounted equipment	Main communications trench	Common trench	See base standards and trough standards (Volume 7: EPCOR D&T)	7
Pad-mounted equipment	Communications pedestals	3.0m	Minimum 3.0 m from case of transformer or switching cubicle to case of pedestal, see Note 4 below	
Primary or secondary cables	Communication vault	300mm	Minimum clearance between edge of communication vault and edge of primary or secondary cable	
Power crossings	To the closest power crossing duct	Power crossing	Communications equipment	
Subdomain: Pipeline Rights-of-Ways (Other Than ATCO IP for Servicing the Subdivision)				
Domain Infrastructure	Subdomain Infrastructure	Minimum Clearance	Notes	
Pad-mounted equipment	From edge of right-of-way	10.0m	From edge of pipeline right-of-way to edge of ground grid	7
Power crossings	From edge of right-of-way	5.0m	Power crossing ducts perpendicular to pipeline are to be extended a minimum of 5.0 m from edge of right-of-way to end of crossing duct	

ADDITIONAL NOTES

These are preferred minimum horizontal clearances. Consult with EDTI Land Servicing for discussion of the possibility of any deviation to these approved clearances due to specific circumstances.
Clearances are from centre to centre of furniture, trench or duct unless otherwise noted.
Note 1: See the City of Edmonton Design and Construction Standards Volume 5 – Landscaping ...shallow utilities shall not be placed in Landscaped Road Islands. Written permission for power crossings or pad mounted equipment in Landscaped Road Islands is the responsibility of the developer. Ducts must be continuous and cannot have trees within 1.0 m of the duct. Other plantings such as small shrubs or flowers would be allowed over top of the crossing.
Note 2: If it is mutually agreed that gas is in the same trench as power, refer to refer to EDTI Underground Distribution Standard 6000070046001 for the typical roadway cross-section to use.
Note 3: Where mutually agreed, an approved method of mechanical separation could be used to reduce the crossing from 300 mm (i.e. 5 Party Trenching, using a sleeve, fastened to the I.P. gas line, as mechanical separation and 100 mm of sand between the sleeve and the power cable.).
Note 4: If communications pedestals are placed with 3.0 m from the edge of the ground grid of pad mounted power equipment, the two pieces of equipment will be bonded. A detail drawing is required.
Note 5: Landscaping clearances are for work on City of Edmonton road allowances only. Landscaping clearances on EDTI utility rights-of-way (URW) are as per the URW documents.

City of Edmonton Consolidated Design Exception Form

PROJECT INFORMATION	
Project Title	
Project Limits, Address, LDA Number, Stage Number, Contract Number	
WR# or WO# (if applicable)	
Design Engineer / P.Tech	
Project Manager	
Project Type	<i>Describe the type of civil works project that requires a design exception (i.e. electrical upgrade, drainage installation, road works, etc.)</i>
Exception Requested	<i>Describe the exception you are requesting and identify the standards document (most recent published version/volume), specific text, drawings, and/or section you are requesting exception from? Indicate the design element or combination of elements which the design exception is proposed for (e.g. curb radius; lane width; offset; etc.).</i>

DESIGN EXCEPTION INFORMATION	
Background, Location, Context	<i>Explain the type of exception (e.g. lack of required separation between infrastructure, minimum dimensions not satisfied, etc.) and where it will apply (e.g. located within the Road Right of Way on the north side of street between cross roads; intersection; intersection quadrant; neighbourhood; or within walkway between lot/block numbers). Include a site plan as an attachment. Describe the context of the exception (e.g. adjacent land use, local conditions, street classification, anticipated infrastructure demands, previous projects, or existing design and/or construction components that do not meet current standards)?</i>
Rationale	<i>What is the rationale for the design exception? Include any supporting documents as applicable such as 1) calculations and/or modeling results; 2) supporting detailed engineering drawings (e.g. utilities drawings, plan & profiles, cross-sections, swept path analysis, etc. as attachment pages); and 3) previous documents, amendments, or approvals that provide further justification for the requested exception.</i>
Alternatives Considered	<i>What alternatives (if any) were considered in the decision? What is the benefit of and what are the impacts avoided with the identified solution(s) over other alternatives considered?</i>
Potential Impacts and Risks	<i>What are the potential impacts and risks? Evaluate the potential risks associated with the exception (e.g. health and safety, property damage, etc.), including potential impacts to the City/EPCOR related to the service life of infrastructure, operation and maintenance requirements, and overall performance. Include safety risk level (e.g. marginal, nominal, substantive).</i>
Mitigation Measures	<i>What proposed/additional mitigation measures are being included to reduce and offset the potential impacts and risks of the exception (e.g. signage, vehicle restrictions, etc.)? Identify each risk and their details, including supporting calculations (be conservative in approach).</i>
Supporting Information (if applicable)	<i>What (if any) additional supporting documents, data, or technical resources were used in making the decision (e.g., research papers, best management practices, other municipal/provincial/federal guidelines, etc.)?</i>

SUBMITTED BY:			
Name			Authentication (required)
Title			Validation (required)
Company			
Primary Contact			
Date of Submission			
Inspector Name (if applicable)			
	I certify the information provided on and attached to this application is accurate and complete. All drawings, documents, details, specifications and supporting information contained in this application pertain to the project that is the subject of this application.		
Signature(s)	Developer/Consultant Representative	Inspector (if applicable)	
Date(s)			

Internal City / EPCOR Use Only				
ACCEPTANCE / REJECTION				
Decision	Accepted ☐	Rejected ☐		
INTERNAL SIGN OFF				
	Designer	Engineer	Manager	Comments
Name				
Title				
Department				
Primary Contact				
Date				
Signature				
Sign Off Requirements:	Volume 2: Design Reviewer, Supervisor (Manager) Volume 3: Design Reviewer, Engineering Reviewer, Land Servicing Manager Volume 4: Volume 5: Volume 6: Volume 7: Volume 8:			

Disclaimer: Unless prior written approval has been obtained, developers or their representatives must follow and meet all of the requirements within the applicable design standards. This exception approval request is project specific and does not apply to other projects. All other requirements not varied by this exception shall continue to apply, including, but not limited to, other applicable guidelines, standards, codes, agreements, and contracts.