

# HVAC: Commercial Interim Inspection (Concealed Duct Systems)

Safety Codes, Permits and Inspections

3rd Floor, Edmonton Tower  
10111 104 Ave NW  
Edmonton AB T5J 0J4  
[edmonton.ca](http://edmonton.ca) or 311

The logo for the City of Edmonton, featuring the word "Edmonton" in white text on a blue square background.

Checklist  
COE-SCPI-CHKL-0015

## **When to use this checklist**

This inspection is required before concealment (drywall, T-bar, shafts, in-slab duct) of installed HVAC systems.

## **Prepare**

Learn about [how to prepare for your inspection](#).

## **Check**

The following are the most common items audited during this inspection. However, the list is not exhaustive. The work must meet all the applicable codes and standards.

- City-reviewed permit plans and specifications in legible form are available on site
- All interim work is completed in accordance with city-reviewed plans and permit conditions
- HVAC systems are installed, and framing is complete
- All fire closures and smoke dampers are in place
- All systems are sealed and insulated where required