

## **When to use this checklist**

This inspection is necessary to view all HVAC work above the basement level.

Request this inspection when all HVAC exhaust, intake, supply and return air ducts are installed and prior to drywall enclosure of the floors above the basement or lowest level (pre-concealment)

## **Prepare**

Learn about [how to prepare for your inspection](#).

## **Check**

The following are the most common items audited during this inspection. However, the list is not exhaustive. The work must meet all the applicable codes and standards.

- Roof flashings for exhaust termination clearance
- Intake/exhaust hood locations/clearances
- Required documentation on site regarding equipment zoning, capacities, efficiencies and primary ventilation fan location
- Ductwork system review (sealing, sizing and location)
- Required ventilation equipment (KE/bath fans/HRV duct system)
- Heat losses completed using F-280
- Mechanical ventilation system manufacturers' information on site
- All piping that is part of a recirculating service water heating loop is covered with piping insulation that is at least 12 mm thick