



## Interior Solid Fuel Appliance - Final Building Inspection

Request this inspection when the Appliance is installed, prior to operation.

### **Prepare**

Learn about [how to prepare for your inspection](#).

### **Check**

The following are the most common items that are audited during this inspection. This list is not exhaustive. Compliance with the applicable codes and standards is required.

- Carbon Monoxide (CO) Alarm
- Installation Manual is on site for review
- CSA approval stamp located on the appliance and accessible
- Combustible material shall not be placed on or near the face of a fireplace: -within 150mm (6 inches) of the fireplace opening, and 300mm (12 inches) from the top of the opening and where a combustible material projects more than 38mm (1.5 inches). non combustible hearth extension 400mm (16 inches) in front of the fireplace opening and not less than 200 (8 inches) beyond opening.