

Plumbing - Final Inspection

This inspection is necessary when the plumbing work has been completed. After groundworks and stacks are completed satisfactorily.

Prepare

Learn about how to prepare for your [Residential](#) or [Commercial](#) inspection.

Check

The following are the most common items audited during this inspection. However, the list is not exhaustive. The work must meet all the applicable codes and standards.

- All fixtures and faucets are installed and operational
- Previously identified deficiencies are corrected
- Supply and drain connections are complete
- Grease interceptors, indirect connections, and water service/supply backflow devices may be required.