

Temporary Gas Heat Inspection

This inspection is necessary when Temporary Heating supply and appliances have been installed, before being put into operation.

Prepare

Learn about how to prepare for your [Residential](#) or [Commercial](#) inspection.

Check

The following are the most common items audited during this inspection. However, the list is not exhaustive. The work must meet all the applicable codes and standards.

- Piping has been installed and meets the CSA B149.1 Natural Gas and Propane Installation Code and the CSA B149.2 Propane Storage and Handling Code
- Regulators have the proper clearances to windows and are not located inside the building.
- Heaters have the proper clearances to combustibles
- Temp furnaces, if applicable, have:
 - Plenum shields
 - Furnace filter installed
 - Proper venting through a window